


	A	B	C	D	E	F	G	H	I	J
0										
1										
2	Documentation for solution TwinCAT SAFETY Safety									
3	Project CRC: 0x61D2									
4	Programmer: Print Name Signature Date									
5	Customer: Print Name Signature Date									
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH						
Editor		pc								
Plot		09/05/2019								

	A	B	C	D	E	F	G	H	I	J
0	Table of Contents									
	Target System				2					
	Alias Device Overview				3					
	Group : TwinSafeGroup1				4					
1	Term 4 (EL1904) - Module 1 (FSOES)				5					
	Term 5 (EL1904) - Module 1 (FSOES)				8					
	Term 6 (EL2904) - Module 1 (FSOES)				11					
	Standard Variables Table				14					
2	Function Block Overview				15					
	Group : TwinSafeGroup1				16					
	Network : Network1				20					
	FBEstop1				21					
3										
4										
5										
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH		Table of Contents				
Editor		pc								
Plot		09/05/2019								
						Page Number: 1				

Target System



Platform: EL6900

Parameters

Version number: 1
Serial Number: 261285
Type: EL6900, TwinSAFE PLC
Product/Revision: EL6900-0000-0016
Auto Inc Addr: 65535
EtherCAT Addr: 1002
Previous Port: B1001

Safety Project

Project CRC: 0x61D2

Safe address: 1

Switch setting:

	1	2	3	4	5	6	7	8	9	10
On	☒	☒	☒	☒	☒	☒	☒	☒	☒	☒
Off	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐

	A	B	C	D	E	F	G	H	I	J
0	Group : TwinSafeGroup1									
1										
2										
3										
4										
5										
Date	09/05/2019		BECKHOFF Beckhoff Automation GmbH		Group : TwinSafeGroup1					
Editor	pc									
Plot	09/05/2019				Page Number: 4					

Term 4 (EL1904) - Module 1 (FSOES)


Type: 4 digital inputs (EtherCAT)

EtherCAT Parameter

Type: EL1904, 4 Ch. Safety Input 24V, TwinSAFE
Product/Revision: EL1904-0000-0016
Auto Inc Addr: 65534
EtherCAT Addr: 1003
Identification Value:
Previous Port: B1002


TwinSAFE Connection Parameter

Name: Message_3
Conn-No: 1
Conn-Id: 3
FSOE Watchdog: 100
Mode: FSoE_master



FSoE address: 2

Switch setting:



	A	B	C	D	E	F	G	H	I	J
0	Term 4 (EL1904) - Module 1 (FSOES)									
1	8000:01 Operating Mode: digital (0) 8001:01 Sensor test Channel 1 active: TRUE (1) 8001:02 Sensor test Channel 2 active: FALSE (0) 8001:03 Sensor test Channel 3 active: FALSE (0) 8001:04 Sensor test Channel 4 active: FALSE (0) 8002:01 Logic of Channel 1 and 2: single logic channel 1/2 (0) 8002:03 Logic of Channel 3 and 4: single logic channel 3/4 (0)									
2										
3										
4										
5										
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH		Term 4 (EL1904) - Module 1 (FSOES)				
Editor		pc								
Plot		09/05/2019		Group : TwinSafeGroup1					Page Number: 6	

Term 5 (EL1904) - Module 1 (FSOES)


Type: 4 digital inputs (EtherCAT)

EtherCAT Parameter

Type: EL1904, 4 Ch. Safety Input 24V, TwinSAFE
Product/Revision: EL1904-0000-0016
Auto Inc Addr: 65533
EtherCAT Addr: 1004
Identification Value:
Previous Port: B1003


TwinSAFE Connection Parameter

Name: Message_4
Conn-No: 2
Conn-Id: 4
FSOE Watchdog: 100
Mode: FSoE_master



FSoE address: 3


Switch setting:



	A	B	C	D	E	F	G	H	I	J
0	Term 5 (EL1904) - Module 1 (FSOES)									
1	8000:01 Operating Mode: digital (0) 8001:01 Sensor test Channel 1 active: TRUE (1) 8001:02 Sensor test Channel 2 active: FALSE (0) 8001:03 Sensor test Channel 3 active: FALSE (0) 8001:04 Sensor test Channel 4 active: FALSE (0) 8002:01 Logic of Channel 1 and 2: single logic channel 1/2 (0) 8002:03 Logic of Channel 3 and 4: single logic channel 3/4 (0)									
2										
3										
4										
5										
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH		Term 5 (EL1904) - Module 1 (FSOES)				
Editor		pc								
Plot		09/05/2019				Group : TwinSafeGroup1				
						Page Number: 9				

Term 6 (EL2904) - Module 1 (FSOES)

Type: 4 digital outputs (EtherCAT)



EtherCAT Parameter


Type: EL2904, 4 Ch. Safety Output 24V, 0.5A, TwinSAFE
Product/Revision: EL2904-0000-0016
Auto Inc Addr: 65532
EtherCAT Addr: 1005
Identification Value:
Previous Port: B1004

TwinSAFE Connection Parameter

Name: Message_5
Conn-No: 3
Conn-Id: 5
FSoE Watchdog: 100
Mode: FSoE_master

FSoE address: 4

Switch setting:



	A	B	C	D	E	F	G	H	I	J						
0	Standard Variables Table															
1	<table><tr><th>Alias Device</th><th>Information</th></tr><tr><td>ErrorAcknowledgement</td><td>Type : BIT From : - To : - TwinSafeGroup1.Err Ack (TwinSafeGroup1)</td></tr><tr><td>Run</td><td>Type : BIT From : - To : - TwinSafeGroup1.Run/Stop (TwinSafeGroup1)</td></tr></table>										Alias Device	Information	ErrorAcknowledgement	Type : BIT From : - To : - TwinSafeGroup1.Err Ack (TwinSafeGroup1)	Run	Type : BIT From : - To : - TwinSafeGroup1.Run/Stop (TwinSafeGroup1)
Alias Device	Information															
ErrorAcknowledgement	Type : BIT From : - To : - TwinSafeGroup1.Err Ack (TwinSafeGroup1)															
Run	Type : BIT From : - To : - TwinSafeGroup1.Run/Stop (TwinSafeGroup1)															
2																
3																
4																
5																
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH		Standard Variables Table										
Editor		pc														
Plot		09/05/2019				Group : TwinSafeGroup1			Page Number: 14							

A		B		C		D		E		F		G		H		I		J	
0	Function Block Overview																		
	Group : TwinSafeGroup1 Network : Network1 FBEstop1																		
1																			
2																			
3																			
4																			
5																			
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH				Function Block Overview											
Editor		pc																	
Plot		09/05/2019																	
																		Page Number: 15	

	A	B	C	D	E	F	G	H	I	J
0	Group : TwinSafeGroup1									
1	Network1									
2										
3										
4										
5	Map State: True Map Diag: True									

Map Diag: True

A

B

C

D

E

F

G

H

I

J

0

1

2

3

4

5

Group : TwinSafeGroup1

Network1

safeEstop
FBEstop1

1

restartment Restart

inputCanal1 EStopIn1
EStopIn2
EStopIn3
EStopIn4
EStopIn5
EStopIn6
EStopIn7
EStopIn8

EDM1
EDM2

Error

Delay Time (ms)
100

EStopOut
EStopDelOut

outputStop

Map State: True


Map Diag: True

Crop: 1

	A	B	C	D	E	F	G	H	I	J
0	Group : TwinSafeGroup1									
1										
2										
3										
4										
5	Map State: True Map Diag: True Crop: 2									

[illegible]

Map Diag: True



	A	B	C	D	E	F	G	H	I	J								
0	FBEstop1 Type: safeEstop <table><tr><th>FunctionBlockPort</th><th>Connection Name</th></tr><tr><td>Restart</td><td>AssignedVariable : rearmament : Term 5 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)</td></tr><tr><td>EStopIn1</td><td>AssignedVariable : inputCanal1 : Term 4 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)</td></tr><tr><td>EStopOut</td><td>AssignedVariable : outputStop : Term 6 (EL2904) - Module 1 (FSOES).OutputChannel1 (TwinSafeGroup1)</td></tr></table>										FunctionBlockPort	Connection Name	Restart	AssignedVariable : rearmament : Term 5 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)	EStopIn1	AssignedVariable : inputCanal1 : Term 4 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)	EStopOut	AssignedVariable : outputStop : Term 6 (EL2904) - Module 1 (FSOES).OutputChannel1 (TwinSafeGroup1)
FunctionBlockPort	Connection Name																	
Restart	AssignedVariable : rearmament : Term 5 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)																	
EStopIn1	AssignedVariable : inputCanal1 : Term 4 (EL1904) - Module 1 (FSOES).InputChannel1 (TwinSafeGroup1)																	
EStopOut	AssignedVariable : outputStop : Term 6 (EL2904) - Module 1 (FSOES).OutputChannel1 (TwinSafeGroup1)																	
1																		
2																		
3																		
4																		
5																		
Date		09/05/2019		BECKHOFF Beckhoff Automation GmbH		FBEstop1												
Editor		pc																
Plot		09/05/2019				Group : TwinSafeGroup1; Network : Network1				Page Number: 22								